


**SUPPLIER** NIEDAX France  
Avenue de la Ferme du Roy  
62404 BETHUNE  
France

**OBJECT** Conformity with the standard IEC 61537


**DESCRIPTION** Steel Cable Ladders NIEDAX France

**TYPE** SR  
HERCULE  
ATLAS


**DATE** 2012-04-24



SR



HERCULE



ATLAS

Tests :

Object : verification of the products normative compliance

Reference Standard : IEC 61537 Edition 2 (2006-10)

Tests : accordind to § 11,1 Electrical Continuity

Product characteristics : cable ladders with independent straight coupler

Conclusion : all samples tested are conform to standard requirements

**We certify that NIEDAX France Cable Ladders have an electrical continuity  
in accordance with the § 11 "Electrical Properties" of the IEC 61537 standard Edition 2006.**

**VALIDATION**

Name : DELFORGE D.

Fonction : R&D Project manager

DATE : 24/04/2112

VISA :